



**Government Of West Bengal**  
**Office Of The Divisional Fire Officer,Purulia**  
**West Bengal Fire & Emergency Services**  
**Purulia Fire Station, Ranchi Road,Purulia, Pin:- 723101**

Memo no.:IND/WB/FES/20182019/32018

Date: 29-03-2021

**From:**  
**Divisional Fire Officer,Purulia**  
**West Bengal Fire & Emergency Services**

**To: A.G.P.N Convent & E.R. School.**  
**Mouza - Chakda, R.S Plot no. 2660, 2661, 2660/3448, J.L no. 42, P.S Purulia(M), Dist. Purulia, Pin - 723202.**

**Sub: Renewal of Fire Safety Certificate for the existing construction of G+1 storied building under group educational, in favour of A.G.P.N Convent & E.R. School, at the Premises/Holding no. Nil, Mouza - Chakda, R.S Plot no. 2660, 2661, 2660/3448, J.L no. 42, P.S Purulia(M), Dist. Purulia, Pin - 723202.**

This is in reference to your application no. 0125191211600001 dated 27-03-2021 regarding the Renewal of Fire Safety Certificate for the existing construction of G+1 storied building under group educational, in favour of A.G.P.N Convent & E.R. School, at the Premises/Holding no. Nil, Mouza - Chakda, R.S Plot no. 2660, 2661, 2660/3448, J.L no. 42, P.S Purulia(M), Dist. Purulia, Pin - 723202.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

**Recommendation:**

1. Driveway must be free of any type of obstruction for easy movement of fire appliances. No parking will be allowed on the drive way.
2. The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.
3. To eliminate risk of fire hazard, good housekeeping both for inside and outside of the building shall be strictly maintained.
4. A fire control room including a closed-circuit TV system will have to be maintained which observe all floor of the building.